


CAN-Bus Aborts for Shaker Testing

OVERVIEW

The CAN bus (Controller Area Network bus) protocol is a peer-to-peer communication standard for automotive devices without relying on a complicated central computer. It is configured with two wires (CAN high and CAN low) which vary in voltage to communicate a bit series of 1's and 0's. CAN bus was initially designed in 1990, with the ISO standard released in 1993. Using CAN bus, an electronic car component (ex: car battery, engine control unit, etc.) can communicate any arbitrary data such as its temperature or working status. A DBC file is used to encode and decode the 1's and 0's into meaningful data, which can be a different mapping for each customer. EDM supports integration with CAN bus signals for monitoring and Alarm / Abort purposes. Given a customer's DBC file and custom-built Crystal Instruments USB CAN adapter, CAN bus alarm and abort rules can be configured during a vibration test. For example, a User running vibration tests on an EV battery can now configure EDM to monitor the battery's temperature and stop or pause the test when the temperature matches or exceeds a particular value.



CANBus Interface In EDM




To read CAN bus signals from the UUT, first connect the CAN Bus USB adapter to the PC running EDM. On the other end of the CAN bus adapter, use the screw terminals to connect the CAN high (CANH)

and CAN low (CANL) wires in the CAN1 section. The adapter should light up upon detecting CAN bus signals.

Driver for PCAN-USB Adapter (PEAK SYSTEMS)

When using the Peak Systems USB adapter, please refer to the Peak Systems website to download necessary drivers and documentation. **This step should ideally be done before proceeding further and interfacing with EDM.**

Peak Systems website URL: <https://www.peak-system.com/PCAN-USB.199.0.html?&L=1>





The screenshot shows the 'Downloads' section of the Peak Systems website. It includes links for:

- Device driver setup for Windows: A link to a PEAK-System installation package for Windows 10, 8.1 (32/64-bit) with tools like PEAK-CPL, PCAN-View, PLIN-View Pro, and Virtual PCAN-Gateway. It includes a 'Download' button.
- Device driver for Linux: A link to device drivers for PEAK CAN interfaces running on Kernel 2.6 and higher, with a 'Website' button.
- PCAN-USB manual: Links for German and English versions.
- PCAN-View: A link to Windows software for displaying, transmitting, and recording CAN and CAN FD messages, with a 'Download' button.

Configuring CANBus On EDM

Click on **Setup > CANBus** to open the CAN-Bus window, which contains all settings and functionality related to CAN bus.





There are several modes that can be used for the CAN-Bus window

Normal mode: Used when connecting the Crystal Instruments CAN-Bus USB adapter to the PC running EDM. If the USB adapter is installed, you should be able to click Open to locate the DBC file in the filesystem

Listen only mode: A similar mode as “Normal mode” where only CAN-Bus signals can be listened to (no sending allowed).

Self-test mode: Used when connecting the Crystal Instruments CAN-Bus USB adapter without a CAN-bus node on the other end. Provides a convenient way to “self-test” certain CAN-Bus signals arriving over the wire.

PCAN-USB: Used when connecting the Peak Systems PCAN-USB adapter to the PC running EDM. If the USB adapter is installed, you should be able to click Open to locate the DBC file in the filesystem.

Baud rate: The rate at which data is transmitted over the network. Must match the Baud rate of the external CAN bus device.

DBC File: The .DBC file that describes the data transmitted over CAN bus. Necessary to decode the bits into meaningful information.

Record File: Specifies the file location for storing recorded CAN bus data (can be turned ON or OFF).


Viewing Raw Data in CANBus

The Raw Data tab in the CAN-Bus window shows a stream of incoming raw CAN bus data. For instance, in the below image, we can see that multiple data sets can be received from a CANbus and each of them is associated with an ID and the data being transferred.

Number	Time	ID	Type	Format	Data	Count
0	2023-03-20 12:00:22:3850	1	Standard	Data	00 00 00 08	864
1	2023-03-20 11:46:03:0060	319	Standard	Data	AB CDEF 01 00 00 00 00	11

Sending Data in CANBus

Below the Raw Data tab is a configuration for sending CAN-Bus data. Click on Config to open the “Send Configuration” window.




Frames of CAN bus data can be configured with the desired ID (in Hexadecimal) and Data body.

Frame type: supports “Standard frame” and “Extended frame”

Frame format: supports “Data Frame” and “Remote frame”

Signal List in CANBus

The Signal List window visualizes the uploaded DBC file as a human-readable list of nested entries.




Filter through the signals in your DBC file using the Search box above. Click on the **View** icon to see more details about the configured CAN bus entry. Enable the **Measure** checkbox to enable it in the

Signal Display tab.

Alarms and Aborts in CANBus

The **Signal Display** tab lists all the CAN Bus signals which have been enabled by checking the **Measure** checkbox. This is the page where the CAN bus values can be configured to trigger a “CANBus Abort” or “CANBus Alarm” event that will be handled later in **Event Action Rules**. For instance, in the below image, the test will abort when the physical value exceeds the **High Abort Value**.



Click on the **Config** icon for each given entry to configure the Alarm / Abort thresholds.

Low and High limits are supported, as well as matching for custom values (“Alarm Values” / “Abort Values”).

Simple mode: For a simple enlarged view of the limits, right-click on the entries and select “Simple display mode”


The screenshot shows two tabs: 'Signal Display' and 'PLC'. In the 'Signal Display' tab, there are two entries: 'minModuleTemperature' and 'maxModuleTemperature', both with 'V' as the unit. A dropdown menu is open over the first entry, showing 'Simple display mode' and 'Config'. In the 'PLC' tab, there is a table with columns 'Name', 'PhysicalValue', and 'Unit'. The same two entries are listed: 'minModuleTemperature' and 'maxModuleTemperature', both with 'V' as the unit. A red arrow points from the 'Simple display mode' dropdown in the Signal Display tab to the 'PhysicalValue' column in the PLC tab, indicating a configuration link between the two.

Event Action Rules in CANBus

Use the **Event Action Rules** page under **Setup > Test Config** to finalize the downstream actions for EDM to take once a CAN bus Alarm or Abort has been triggered. Event Action Rules refers to an innovative feature developed by Crystal Instruments offering the flexibility to define arbitrary actions when certain events happen. When CAN bus is enabled, two additional Event names will appear: "CAN-Bus Abort" and "CAN-Bus Alarm". These event names correspond to the Alarm and Abort criteria configured in the previous section.

Click on **Add action**, **Edit action**, or **Remove action** to further configure the list of actions for EDM to take after an Abort or Alarm is enabled.

This is the final step in the CANbus configuration. EDM is now ready to interface with CANbus data and take necessary actions such as Abort or Alarm during the tests.



From:

<https://help.go-ci.com/> - **Crystal Instruments Help**

Permanent link:

<https://help.go-ci.com/vcs:can-bus>

Last update: **2023/08/29 21:16**